




KELLER
associates



ADDENDUM NO. 3

to the

CONTRACT DOCUMENTS

for

**CITY OF WOOD VILLAGE, OREGON
WOOD VILLAGE GREEN MOBILE HOME PARK**

This Addendum dated January 12, 2017, is for all persons preparing bids for the above referenced project and as such shall be made a part of the Contract Documents.

All changes, corrections, deletions and/or additions to the initial bidding documents enumerated herein shall be included in the Bidder's Proposal. In case of any conflict between the drawings, specifications, and this Addendum, this Addendum shall govern.

The Bidder shall acknowledge the receipt of this Addendum in the appropriate place in the Bidder's Proposal. Failure to acknowledge the receipt of this Addendum may cause a Bid to be considered non-responsive.

Item Description

- 3-1 Replace Water Note 2 of Sheet C-002 of the Construction Drawings (Special Provisions) with the following: "WHERE THRUST BLOCKS ARE NOT USED, WATER PIPELINE SHALL BE CONSTRUCTED WITH RESTRAINED JOINTS USING STANDARD MECHANICAL JOINT WITHIN THREE (3) PIPE LENGTHS OF ANY FITTING. RESTRAINT GLAND, RESTRAINT DEVICES FOR MJ FITTINGS, AND APPURTENANCES MUST CONFORM TO ANSI/AWWA C111/A21.11 OR ANSI/AWWA C153/A21.53. RESTRAINT DEVICES SHALL BE EBAA IRON SERIES 2000 PV OR APPROVED SUBSTITUTION MEETING ASTM F1764, WITH IDENTIFICATION NUMBER DENOTING YEAR/DAY/PLANT/SHIFT CAST INTO EACH GLAND BODY.



EXPIRES: 12/31/18

KELLER ASSOCIATES, Inc.
707 13th Street SE, Suite 280
Salem, OR 97301

**Receipt Confirmation
for the**

Wood Village Green Mobile Home Park

Addendum No. 3

Total Pages: 3

(including this receipt confirmation)

Whether or not you intend to bid, it is extremely important that you confirm you received this email/fax by signing below and faxing this confirmation sheet to the City of Wood Village at scotts@ci.wood-village.or.us or (503) 489-6862.

I acknowledge receipt of Addendum No. 1 for the above referenced project.

Date: _____

Company

Signature

Title

Print Name

- Note: 1) Contractor must also acknowledge receipt of Addendum on Bid Form.
- 2) Failure of any bidder to receive any such addenda shall not relieve such bidder from any obligation under the bid as submitted. All addenda so issued shall become part of the contract documents. It is the responsibility for all prospective bidders to check with the Engineer prior to submitting his bid to verify whether or not any addenda have been issued for the project.